



Product certificate K-0212629/01

Issued 2023-12-01

Replaces -

Page 1 of 2

Stainless steel tubes NUMEPRESS

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

ISOTUBI SL

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K762 "Steel pipes for transport of drinking water" dated 2018-01-16.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

288171015

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
ISOTUBI SL
Pol. Ind. Comte de Sert. Av. Can Company 15
08755 CASTELLBISBAL
Spain
Tel. +34 937711697
isotubi@isotubi.com
www.isotubi.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Stainless steel tubes NUMEPRESS

Technical specification

TIG welded stainless steel tubes of EN 10088 in material types 1.4401 / 1.4404 (AISI 316L) and 1.4301 / 1.4307 (AISI 304L) according to delivery conditions as specified in the European Standard EN 10312 for:

- Stainless steel tubes dimensions DN12 mm x 1.0 mm to an up to and including DN108 x 2.0 mm

Fitness for contact with drinking water


This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

Marking

The Kiwa®-mark products are marked with the word mark "KIWA ", or "KIWA watermark"

Place of the mark: on the exterior of the pipe, at maximum intervals of 300 mm.

Compulsory specifications:

- product name or manufacturer designation
- Production specification
- outside diameter
- type of material (steel grade)
- Reference to relevant European standard EN10312

Method of marking:

Non-erasable;

visible after assembly.

APPLICATION AND USE

The products are intended to be used for the transport of drinking water in combination with fittings according to BRL-K774 at a working pressure of 1MPa (1.000 kPa), with a water temperature up to 65°C and a maximum water temperature up to 90°C for a period of maximum 1 hour.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- ISOTUBI SL

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.